



ANNUAL REPORT

| | |
|--|--------------------------------------|
| Drinking-Water System Number: | 210000906 |
| Drinking-Water System Name: | Lambton Area Water Supply System |
| Drinking-Water System Owner: | Lambton Area Water Supply System |
| Drinking-Water System Category: | Large Municipal Residential System |
| Period being reported: | January 1, 2010 to December 31, 2010 |

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people? Yes [] No []

Is your annual report available to the public at no charge on a web site on the Internet? Yes [] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

- www.lawss.org
- Lambton Area Water Supply System**
1215 Fort St. Sarnia, ON N7V 1M1
519-344-7429
- Sarnia City Hall**
255 N Christina St. Sarnia, ON N7T 7N2
519-332-0330
- Village of Point Edward Municipal Office**
135 Kendall St. Pt. Edward, ON N7M 4G6
519-337-3021
- St. Clair Civic Centre**
1155 Emily St. Mooretown, ON N0N 1M0
519-867-2021
- Town of Plympton-Wyoming Municipal Office**
546 Niagara St. Wyoming, ON N0N 1T0
519-845-3939
- Township of Warwick Municipal Office**
6332 Nauvoo Rd. Watford, ON N0M 2S0
519-849-3926
- Lambton Shores Municipal Office**
19 Ann St. Forest, ON N0N 1J0
519-786-2335
- Township of Brooke-Alvinston Municipal Office**
3236 River St. P.O. Box 28 Alvinston, ON N0N 1A0
519-898-2173

Complete for all other Categories.

Number of Designated Facilities served:

N/A

Did you provide a copy of your annual report to all Designated Facilities you serve?

Yes [] No [] N/A []

Number of Interested Authorities you report to:

N/A

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?

Yes [] No [] N/A []



The following is a list of all Drinking-Water Systems which receive all (or some) of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|--|-------------------------------------|
| City of Sarnia Distribution System (receives SOME of their drinking water from Enniskillen System) | 260003136 |
| Village of Point Edward Distribution System | 210000924 |
| Township of St. Clair Distribution System | 260006464 |
| Town of Plympton –Wyoming Distribution System | 260006594 |
| Township of Warwick Distribution System | 260001799 |
| Lambton Shores Distribution System (receives SOME of their drinking water from this system) | 260006594 |
| Township of Brooke-Alvinston Distribution System (receives SOME of their drinking water from Enniskillen System) | 260040170 |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [] No []

Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method



Describe your Drinking-Water System

Water Treatment Plant:

The Lambton Area Water Supply System (LAWSS) is a direct filtration facility with a maximum rated capacity of 181,844 m³/day. The Water Treatment Plant (WTP) uses chemically assisted filtration with disinfection. The facility consists of an intake system, a low lift pumping system, a treatment system and distribution pumping system that supplies water to seven drinking water systems. Water is drawn into the plant (a zebra mussel chemical control system is available as needed) via a 1675-mm intake pipe, located approximately 100 m into the St. Clair River at a depth of 15 m. The water passes through travelling screens prior to entering the surge wells and pre-disinfection is utilized. Water flows to the low lift pump wet wells where a total of 4 vertical turbine pumps are located and used as needed. The water is then pumped to a common discharge header where coagulant is added and flashed mixed. Powdered activated carbon (PAC) is also applied at this location when needed for taste and odour. The water is then flocculated with polymer being added at the flocculation trains as needed. Water from the flocculators is then sent to be filtered in dual media filters (10 in total). The filter effluents combine into two clearwells via gravity and sodium hypochlorite is added. To increase the contact time, the treated water is diverted to two baffled reservoirs (in series). The water is fluoridated upon exiting the reservoirs. Six vertical turbine pumps are available for supplying water to the distribution system. The water treatment process and distribution components are controlled by a dedicated supervisory control and data acquisition (SCADA) computer system and monitored by certified operators 24 hours a day. Emergency generators powered by diesel are available at the WTP to keep the plant in operation should a power failure occur. The utility serves a large part of Lambton County and has over 200 kilometres of pipeline of various sizes and materials. The LAWSS distribution system has three standpipes and one elevated tower. The East Lambton Booster Station has a water storage capacity of 9,000 m³ and the West Lambton Pumping Station has 90,000 m³ of water storage capacity. The booster stations are controlled and monitored from the Lambton WTP via the SCADA system. Backwash from the dual media filters is treated using a high rate clarification process (ACTIFLO) The clarified water is discharged to the St. Clair River and the settled solid/liquid mixture is sent to the Sarnia Water Pollution Control Plant for final treatment and disposal. This system is referred to as the Residual Management System.

Emergency Water Line connections exist between LAWSS and the following drinking water systems:

- Chatham-Kent - A connection exists at Whitebread Line and Highway #40
- Petrolia - A connection exists at Confederation Line and Ploughing Match Rd.
- Grand Bend - A connection exists at Lakeshore Rd. and the northwest corner of Ipperwash Rd.

List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite** - disinfection
- Hydrofluosilicic Acid** - fluoridation
- Clar+Ion A7 (Aluminum Sulphate)** - coagulation
- Powder Activated Carbon** - taste and odor (when required)
- Polymer 8103+** - filter aid (when required)
- Sodium Bisulfite** - dechlorination for Residual Management System

Note: all water treatment chemicals are NSF/ANSI approved



Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Below is a brief description and a breakdown of monetary expenses incurred

| | |
|---|-----------|
| Repair 36 inch CPP water main on LaSalle Road | \$555,000 |
| Filter rebuild and sweep maintenance | \$100,000 |
| ELPS Corrosion painting | \$ 30,000 |
| Filter 7 and 9 Sluice gate replacement | \$ 69,000 |
| ELPS Pump Control Valve work | \$ 46,700 |
| ELPS Facility Work | \$ 22,500 |
| Main Plant PLC upgrade | \$165,000 |
| Level, Turbidity, UPS equipment replacements | \$173,000 |
| Misc Distribution System repairs (OM) | \$250,000 |

The following are notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|----------------------|---|---------------|------------------------|---|-------------------------------|
| Jan. 8, 2010 | Fluoride | 1.5-1.77 | mg/L | Hydrofluorosilicic acid metering pump was shut down until the 4-20 mA DC signal issues were resolved | Jan. 8 2010 |
| July 27, 2010 | Other Observations: Low Pressure | 80 | kPa | Pressure restored by opening valve (Valve failure in distribution system- controller module fault was corrected) | July 27, 2010 |
| Aug. 27, 2010 | Other observations: Partially untreated water (ruptured coagulant line)reached clearwell | | | Plant low lift shut down, (isolated partially untreated water from clearwell) Repaired coagulant line. Flushed/draind partially untreated water to waste. Disinfectant increased. | Aug 27, 2010 |



Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| Water Type | Number of Samples | Range of E.Coli Or Fecal Results (min #)-(max #) | Range of Total Coliform Results (min #)-(max #) | Number Of Background Samples | Range of Background Results (min#-max#) | Number of HPC Samples | Range of HPC Results (min #)-(max #) |
|------------|-------------------|--|---|------------------------------|---|-----------------------|--------------------------------------|
| Raw | 52 | 0-10fu/100mL | 0-130cfu/100mL | 52 | 0-7200cfu/100mL | | |
| Treated | 52 | 0-0cfu/100mL | 0-0cfu/100mL | 52 | 0-11cfu/100mL | 52 | <10-100cfu/1mL |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| Parameter | Number of Grab Samples | Range of Results (min #)-(max #) |
|---|------------------------|----------------------------------|
| Turbidity | 8760 | 0.02-1.37 NTU |
| Chlorine | 8760 | 1.34-2.35 mg/L |
| Chlorine (distribution) | 8760 | 0.79-2.00 mg/L |
| Fluoride (If the DWS provides fluoridation) | 8760 | 0.22-1.77 mg/L |

Notes: The fluoridation system was out of service due to maintenance on Jan. 8 &12, 2010 and March 4, 2010. Turbidity is measured on each filter effluent line (10 filters) at a frequency greater than is required under O. Reg 170/03 Schedule 6-5. It should be noted that no filter effluent turbidity exceeded the prescribed test result for adverse reporting under Schedule 16-3.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument. The following list of parameters are tested on the Residual Management System’s water discharge to the St. Clair River (commissioned on November 13, 2006)

| Date Sampled | Parameter | Sample Type | Result min-max | Unit of Measure |
|--------------|--------------------------|-------------------|----------------|-----------------|
| *Jan –Dec/10 | Total Suspended Solids | Monthly composite | <2-10 | mg/L |
| *Jan –Dec/10 | Aluminum | Monthly composite | 0.023-0.150 | mg/L |
| *Jan –Dec/10 | (Total)Chlorine Residual | Monthly grab | 0-0 | mg/L |



Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|-----------|--------------|--------------|-----------------|------------|
| Antimony | *Jan –Aug/10 | <0.02-0.31 | ppb | No |
| Arsenic | *Jan –Aug/10 | 0.2-0.5 | ppb | No |
| Barium | *Jan –Aug/10 | 13.6-14.1 | ppb | No |
| Boron | *Jan –Aug/10 | 14.6-18.9 | ppb | No |
| Cadmium | *Jan –Aug/10 | <0.003 | ppb | No |
| Chromium | *Jan –Aug/10 | 0.7-0.8 | ppb | No |
| Mercury | *Jan –Aug/10 | <0.02 | ppb | No |
| Selenium | *Jan –Aug/10 | <1 | ppb | No |
| Sodium | *Jan –Aug/10 | 5.67-6.09 | mg/L | No |
| Uranium | *Jan –Aug/10 | .131-.175 | ppb | No |
| Nitrite | *Jan –Dec/10 | < 0.005 | mg/L | No |
| Nitrate | *Jan –Aug/10 | 0.256-0.308 | mg/L | No |

*Note: Inorganic parameters were tested tri-annually, with the exception of nitrites/nitrates which were tested quarterly. If a parameter was detectable the range of detection has been provided and reported in the table above. For interpretation purposes the less than sign (<) indicates the parameter was not detectable at the method detection limit.

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| Location Type | Number of Samples | Range of Lead Results (min#) – (max #) | Number of Exceedances |
|---------------|-------------------|--|-----------------------|
| Plumbing | | | |
| Distribution | | | |

Note: Lead samples were collected in the municipal drinking water system that receives water from the Lambton Area Water Supply System. The local municipal office should be contacted for lead results.



Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Unit of Measure | Exceedance |
|---|--------------|--------------|-----------------|------------|
| Alachlor | *Jan –Aug/10 | < 0.11 | ppb | No |
| Aldicarb | *Jan –Aug/10 | < 0.30 | ppb | No |
| Aldrin + Dieldrin | *Jan –Aug/10 | < 0.067 | ppb | No |
| Atrazine + N-dealkylated metabolites | *Jan –Aug/10 | < 0.12 | ppb | No |
| Azinphos-methyl | *Jan –Aug/10 | < 0.21 | ppb | No |
| Bendiocarb | *Jan –Aug/10 | < 0.13 | ppb | No |
| Benzene | *Jan –Aug/10 | < 0.32 | ppb | No |
| Benzo(a)pyrene | *Jan –Aug/10 | < 0.004 | ppb | No |
| Bromoxynil | *Jan –Aug/10 | < 0.33 | ppb | No |
| Carbaryl | *Jan –Aug/10 | <0.16 | ppb | No |
| Carbofuran | *Jan –Aug/10 | < 0.37 | ppb | No |
| Carbon Tetrachloride | *Jan –Aug/10 | < 0.16 | ppb | No |
| Chlordane (Total) | *Jan –Aug/10 | < 0.11 | ppb | No |
| Chlorpyrifos | *Jan –Aug/10 | < 0.18 | ppb | No |
| Cyanazine | *Jan –Aug/10 | < 0.18 | ppb | No |
| Diazinon | *Jan –Aug/10 | < 0.081 | ppb | No |
| Dicamba | *Jan –Aug/10 | < 0.2 | ppb | No |
| 1,2-Dichlorobenzene | *Jan –Aug/10 | < 0.41 | ppb | No |
| 1,4-Dichlorobenzene | *Jan –Aug/10 | < 0.36 | ppb | No |
| Dichlorodiphenyltrichloroethane (DDT) + metabolites | *Jan –Aug/10 | < 0.14 | ppb | No |
| 1,2-Dichloroethane | *Jan –Aug/10 | < 0.35 | ppb | No |
| 1,1-Dichloroethylene (vinylidene chloride) | *Jan –Aug/10 | < 0.33 | ppb | No |
| Dichloromethane | *Jan –Aug/10 | < 0.35 | ppb | No |
| 2,4-Dichlorophenol | *Jan –Aug/10 | < 0.15 | ppb | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | *Jan –Aug/10 | < 0.19 | ppb | No |
| Diclofop-methyl | *Jan –Aug/10 | < 0.4 | ppb | No |
| Dimethoate | *Jan –Aug/10 | < 0.12 | ppb | No |
| Dinoseb | *Jan –Aug/10 | < 0.36 | ppb | No |
| Diquat | *Jan –Aug/10 | < 1.0 | ppb | No |
| Diuron | *Jan –Aug/10 | < 0.087 | ppb | No |
| Glyphosate | *Jan –Aug/10 | < 6 | ppb | No |
| Heptachlor + Heptachlor Epoxide | *Jan –Aug/10 | < 0.11 | ppb | No |
| Lindane (Total) | *Jan –Aug/10 | < 0.056 | ppb | No |



| | | | | |
|---|--------------|---------|-----|----|
| Malathion | *Jan –Aug/10 | < 0.91 | ppb | No |
| Methoxychlor | *Jan –Aug/10 | < 0.14 | ppb | No |
| Metolachlor | *Jan –Aug/10 | < 0.092 | ppb | No |
| Metribuzin | *Jan –Aug/10 | < 0.12 | ppb | No |
| Monochlorobenzene | *Jan –Aug/10 | < 0.3 | ppb | No |
| Paraquat | *Jan –Aug/10 | < 1 | ppb | No |
| Parathion | *Jan –Aug/10 | < 0.18 | ppb | No |
| Pentachlorophenol | *Jan –Aug/10 | < 0.15 | ppb | No |
| Phorate | *Jan –Aug/10 | < 0.11 | ppb | No |
| Picloram | *Jan –Aug/10 | < 0.25 | ppb | No |
| Polychlorinated Biphenyls(PCB) | *Jan –Aug/10 | < 0.04 | ppb | No |
| Prometryne | *Jan –Aug/10 | < 0.23 | ppb | No |
| Simazine | *Jan –Aug/10 | < 0.15 | ppb | No |
| THM (NOTE: show latest annual average) | *Jan –Dec/10 | 38 | ppb | No |
| Temephos | *Jan –Aug/10 | < 0.31 | ppb | No |
| Terbufos | *Jan –Aug/10 | < 0.12 | ppb | No |
| Tetrachloroethylene | *Jan –Aug/10 | < 0.35 | ppb | No |
| 2,3,4,6-Tetrachlorophenol | *Jan –Aug/10 | < 0.14 | ppb | No |
| Triallate | *Jan –Aug/10 | < 0.1 | ppb | No |
| Trichloroethylene | *Jan –Aug/10 | < 0.43 | ppb | No |
| 2,4,6-Trichlorophenol | *Jan –Aug/10 | < 0.25 | ppb | No |
| 2,4,5-Trichlorophenoxy acetic acid (2,4,5-T) | *Jan –Aug/10 | < 0.22 | ppb | No |
| Trifluralin | *Jan –Aug/10 | < 0.12 | ppb | No |
| Vinyl Chloride | *Jan –Aug/10 | < 0.17 | ppb | No |

***Note:** All Organic parameters were tested tri-annually except THM’s which were tested quarterly. If a parameter was/is detectable the range of detection has been provided and reported in the table above. Also: for interpretation purposes the less than sign (<) indicates the parameter was not detectable at the method detection limit.

Note: No inorganic or organic parameters exceeded half the standard prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards